

Report Number: PL18136-001A
Model: OSQP-C-3L-27K7-3R-UL (Light Engine)
Issue Date: 02/02/2024

Cree Racine Engineering Services Testing Laboratory (RESTL) Photometric Testing and Evaluation Report

Prepared For:


Tammy Lehrmann

Cree Lighting

9201 Washington Avenue

Racine, WI 53406

Prepared By:



Jennifer Rocco, Photometric Test Technician

Approved By:



Meranda Hubbard, Photometric Test Technician

Product Information

Manufacturer	Cree Lighting
Model Number (SKU)	OSQP-C-3L-27K7-3R-UL (Light Engine)
Serial Number	18136
LED Type	SSC STW7C12C-E0

Product Description

OSQP-C Pathway Luminaire (Light Engine), 3L Lumen Package, 2700K 70CRI, Type 3M Rotatable Optics

Driver Information (Where Applicable)

Signify XI030C080V054BSJ1

Length	Width	Height
9.5"	9.5"	6.9"

Sample

The following sample was submitted for evaluation



Key Photometric Data	Sphere Output	Goniophotometer	
Luminous Flux	2608.5	2605.0	lm
Efficacy	132.09	132.10	lm/W
Correlated Color Temperature (CCT)	2744	K	
Color Rendering Index (CRI)	72		
R ₉	-32		
Duv	0.0019		
TM-30 R _f *	76		
TM-30 R _g *	93		
TM-30 R _{cs,h1} *	-16.5%		
S/P Ratio*	1.10		

Electrical Measurements	Sphere		Goniophotometer		
	120V	277V	120V	277V	
Input Wattage	19.75	19.79	19.72	19.82	W
Input Current	0.170	0.075	0.169	0.075	A
Input Voltage	120.05	277.17	120.19	277.05	V
Power Factor	0.968	0.954	0.971	0.954	
Off-State Power	0	0	0	0	W
Total Harmonic Distortion (Voltage)	0.12	0.10	0.09	0.18	%
Total Harmonic Distortion (Amperage)	12.02	10.40	12.55	9.75	%

Note: All photometric measurements taken at 120VAC.

Luminous Intensity Distribution	Goniophotometer	
Max Candela	1701.315	Cd
Angle of Max Candela (Horizontal)	60	°
Angle of Max Candela (Vertical)	61	°

Key Test Parameters	Sphere Output	Goniophotometer	
Stabilization Time	55	30	min
Total Operating Time (Stabilization + Test)	65	50	min
Ambient Temperature	24.53	24.9	°C


Chromaticity Coordinates

x	y	u	v	u'	v'	Duv
0.4595	0.4156	0.2601	0.3528	0.2601	0.5292	0.0019

Color Rendering Index Details

Ra	R1	R2	R3	R4	R5	R6	R7	R8	R9	R10	R11	R12	R13	R14
72	68	82	95	67	67	76	77	42	-32	60	62	48	71	97

Chromaticity Diagram



NOTE: The Chromaticity Diagram shown above references table A1 specification for 7-step quadrangles referenced in ANSI C78.377-2017.

Spectral Distribution


λ (nm)	W/nm
360	0.000030
370	0.000066
380	0.000070
390	0.000048
400	0.000026
410	0.000178
420	0.001145
430	0.004474
440	0.010624
450	0.022420
460	0.014861
470	0.007759
480	0.004362
490	0.004825
500	0.008346
510	0.014682
520	0.020679

λ (nm)	W/nm
530	0.024984
540	0.028405
550	0.032437
560	0.037879
570	0.044749
580	0.051236
590	0.055890
600	0.056999
610	0.054532
620	0.049227
630	0.042394
640	0.035127
650	0.028205
660	0.022057
670	0.016756
680	0.012526
690	0.009270

λ (nm)	W/nm
700	0.006821
710	0.004984
720	0.003623
730	0.002620
740	0.001870
750	0.001351
760	0.000981
770	0.000707
780	0.000516
790	0.000370
800	0.000265
810	0.000189
820	0.000133
830	0.000082


Dominant Wavelength	583	nm
Peak Wavelength	598	nm

Spectral Power Distribution (W/nm)




Zonal Lumen Summary

Zone	Lumens	% of Total	Zone	Lumens
0-20	230.8	8.9	0-10	61.9
0-30	481.1	18.5	10-20	168.9
0-40	824.0	31.6	20-30	250.3
0-60	1885.7	72.4	30-40	342.9
0-80	2576.8	98.9	40-50	472.6
0-90	2605.0	100.0	50-60	589.2
10-90	2543.1	97.6	60-70	498.5
20-40	593.2	22.8	70-80	192.6
20-50	1065.8	40.9	80-90	28.2
40-70	1560.2	59.9	90-100	0.0
60-80	691.1	26.5	100-110	0.0
70-80	192.6	7.4	110-120	0.0
80-90	28.2	1.1	120-130	0.0
90-110	0.0	0.0	130-140	0.0
90-120	0.0	0.0	140-150	0.0
90-130	0.0	0.0	150-160	0.0
90-150	0.0	0.0	160-170	0.0
90-180	0.0	0.0	170-180	0.0
110-180	0.0	0.0		
Total	2605.0 LM	100%		



Roadway Summary	Lumens	% Lamp
Distribution	TYPE II SHORT	
Downward Street Side	1756.9	67.4
Downward House Side	848.2	32.6
Downward Total	2605.1	100.0
Upward Street Side	0.0	0.0
Upward House Side	0.0	0.0
Upward Total	0.0	0.0
Total Lumens	2605.1	100

Luminaire Classification System (LCS)	Lumens	% Luminaire
FL - Front Low (0-30)	282.7	10.9
FM - Front Medium (30-60)	982.2	37.7
FH - Front High (60-80)	481.0	18.5
FVH - Front Very High (80-90)	11.0	0.4
BL - Back Low (0-30)	198.5	7.6
BM - Back Medium (30-60)	422.4	16.2
BH - Back High (60-80)	210.1	8.1
BVH - Back Very High (80-90)	17.2	0.7
UL - Uplight Low (90-100)	0.0	0.0
UH - Uplight High (100-180)	0.0	0.0
BUG Rating*	B1-U0-G1	



Candela Tabulations

	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70
0	662.1	662.1	662.1	662.1	662.1	662.1	662.1	662.1	662.1	662.1	662.1	662.1	662.1	662.1	662.1
1	662.2	664.7	664.7	665.4	666.2	666.8	666.4	666.1	666.6	666.0	665.9	665.7	665.1	664.3	663.3
2	665.7	668.0	668.0	668.3	669.3	669.8	669.3	668.7	669.4	668.4	668.3	667.5	666.8	665.8	664.4
3	668.3	670.8	670.6	671.1	672.0	672.4	671.7	671.3	671.6	670.6	670.0	669.3	668.2	667.1	665.4
4	671.2	673.6	673.2	673.7	674.6	675.0	674.3	673.9	673.8	672.9	672.1	671.3	669.8	668.6	666.9
5	674.0	676.0	675.8	676.1	677.1	677.4	676.9	676.3	676.4	675.4	674.6	673.5	672.0	670.4	668.2
6	676.3	677.7	677.6	678.0	679.0	679.6	679.1	678.5	678.8	677.6	676.7	675.3	673.7	671.9	669.4
7	677.7	678.9	678.8	679.3	680.4	681.0	680.5	680.3	680.4	679.3	678.2	677.0	675.1	673.1	670.2
8	678.9	679.9	679.8	680.4	681.3	682.1	682.0	682.0	682.1	681.2	680.1	678.6	676.5	674.1	670.9
9	679.8	680.1	680.1	680.7	682.1	683.1	683.3	683.5	683.8	682.9	681.8	680.0	677.8	675.0	671.2
10	679.6	679.5	679.5	680.4	682.0	683.5	684.0	684.3	684.8	683.9	683.2	681.2	678.6	675.3	670.7
11	678.6	678.0	678.1	679.1	681.3	683.1	684.1	684.9	685.4	684.7	683.8	681.8	678.9	675.3	670.3
12	676.6	675.6	675.8	677.5	679.9	682.1	684.0	685.1	686.1	685.5	684.6	682.6	679.3	675.3	669.7
13	673.9	673.4	674.0	675.9	678.7	681.5	683.8	685.4	686.9	686.5	685.9	683.6	679.9	675.2	668.6
14	671.5	671.2	672.0	674.3	677.5	680.9	683.6	685.5	687.2	687.1	686.6	683.9	679.7	674.4	666.9
15	669.3	669.1	670.0	672.7	676.7	680.3	683.4	685.3	687.1	687.2	686.8	683.9	679.3	673.5	665.4
16	667.3	666.9	668.4	671.6	676.0	680.1	683.5	685.7	687.4	687.6	687.0	684.3	679.3	672.9	664.0
17	664.6	665.0	666.7	670.4	675.5	680.2	684.1	686.6	688.3	688.1	687.5	684.7	679.4	672.3	662.2
18	662.6	663.7	665.5	669.3	674.9	680.3	684.6	686.9	688.7	688.2	687.4	684.4	678.9	670.9	659.9
19	661.6	662.9	664.7	668.8	674.8	680.3	684.9	687.4	689.1	688.7	687.6	684.3	678.1	669.6	657.7
20	661.0	662.4	664.7	669.1	675.7	681.2	685.7	688.5	690.1	690.0	688.2	684.5	677.7	668.5	655.6
21	661.0	662.6	665.1	670.2	677.1	683.3	687.2	689.8	691.6	691.1	689.4	685.3	677.9	667.7	653.4
22	661.5	663.5	666.2	671.9	679.4	685.7	689.3	691.5	692.6	692.4	690.6	686.2	678.4	667.4	651.6
23	662.7	665.3	668.1	674.3	682.1	688.6	692.0	693.8	694.7	694.3	692.3	687.8	679.4	667.8	650.3
24	664.9	668.1	671.1	677.6	685.6	692.2	695.5	697.3	698.2	697.3	695.2	690.3	681.2	668.1	649.1
25	668.3	671.7	674.5	681.3	689.6	696.1	699.3	701.1	702.3	701.3	698.5	693.1	683.1	668.5	647.9
26	671.7	676.5	679.2	686.3	694.9	701.0	703.6	705.6	706.9	705.9	702.5	696.5	685.6	670.0	647.3
27	676.6	682.0	684.7	691.8	700.4	706.1	708.6	710.6	712.6	711.6	707.6	700.7	688.9	672.2	648.0
28	681.9	687.0	690.1	697.4	706.0	711.4	714.0	715.9	718.6	717.5	713.9	705.4	692.8	674.8	648.5
29	686.6	692.6	696.0	703.7	712.8	717.8	719.8	722.3	724.9	724.1	720.5	711.2	697.0	678.0	649.5
30	693.0	699.9	703.0	711.5	720.6	725.5	727.0	730.1	732.2	732.3	727.8	718.3	702.0	681.9	651.6
31	699.7	707.7	710.7	718.7	728.2	733.1	735.0	737.7	740.2	740.7	736.2	726.1	708.0	686.3	654.6
32	707.5	715.5	718.4	726.6	735.8	740.5	743.2	745.7	748.9	749.0	744.9	734.2	714.8	691.0	657.7
33	716.5	725.5	728.3	736.5	745.4	749.3	752.4	755.8	758.4	758.9	754.3	743.6	722.8	697.4	662.0
34	727.0	737.0	739.8	747.9	756.1	760.5	763.8	767.5	769.1	769.6	764.4	753.6	732.2	704.7	667.5
35	738.2	747.7	749.9	757.5	766.5	771.3	774.9	778.8	780.1	780.4	775.3	763.5	741.6	711.8	673.3
36	749.9	757.8	759.4	767.7	776.9	782.3	786.2	790.4	792.0	791.3	786.2	773.7	751.9	720.3	679.3

Candela Tabulations (Continued)

	75	80	85	90	95	100	105	110	115	120	125	130	135	140	145
0	662.1	662.1	662.1	662.1	662.1	662.1	662.1	662.1	662.1	662.1	662.1	662.1	662.1	662.1	662.1
1	662.7	660.7	661.2	662.6	660.4	659.3	660.6	660.5	660.8	660.9	660.8	660.6	660.1	660.1	659.4
2	663.6	661.3	661.4	662.4	659.8	658.5	659.3	659.1	658.7	658.8	658.3	657.9	656.8	656.6	655.4
3	664.4	661.9	661.7	662.6	659.6	657.8	658.2	657.2	656.3	655.8	654.9	653.7	652.4	651.3	650.2
4	665.5	662.5	662.1	662.5	658.7	656.5	656.5	654.9	653.4	651.9	650.7	648.6	647.0	645.0	643.6
5	666.4	663.0	662.0	661.9	657.7	655.0	654.0	651.9	649.9	647.9	645.7	643.1	640.8	638.5	635.8
6	667.2	663.3	661.7	661.2	656.3	653.1	651.5	649.3	646.5	643.5	640.7	636.9	633.8	630.4	626.3
7	667.7	663.4	661.4	660.5	655.1	651.2	649.0	646.0	642.4	638.4	634.8	629.2	625.1	619.1	614.6
8	668.2	663.1	660.6	659.2	653.3	648.9	646.1	642.0	638.0	632.7	627.7	620.6	614.8	607.7	600.9
9	667.7	662.1	659.0	657.0	650.6	645.7	642.3	637.5	632.8	626.7	619.9	611.7	604.1	595.9	585.7
10	666.6	660.5	656.7	654.1	647.4	642.0	637.9	632.4	626.6	619.1	610.5	600.9	591.0	581.0	569.6
11	665.6	658.8	654.2	651.3	644.0	637.9	633.4	626.3	619.5	609.7	599.5	587.1	575.7	563.2	551.5
12	664.1	656.5	651.1	647.3	639.4	632.8	627.7	619.4	611.2	600.3	587.5	574.1	560.2	547.0	535.0
13	662.3	653.6	647.2	642.5	633.9	626.5	620.7	611.6	602.2	590.2	575.5	561.1	545.3	532.7	519.9
14	659.7	650.4	642.9	637.5	627.9	619.6	612.8	603.0	591.9	577.4	561.5	545.4	529.6	516.2	504.7
15	657.2	646.8	638.7	632.2	622.0	612.6	604.6	593.1	580.3	563.2	546.0	528.8	512.9	499.4	489.5
16	654.5	643.1	633.6	626.1	614.7	604.8	595.5	582.6	567.5	549.8	531.4	514.4	498.8	485.8	476.0
17	651.6	638.7	627.9	619.1	606.4	595.7	584.9	571.4	554.6	536.2	517.9	500.5	485.6	473.6	463.3
18	648.2	634.0	621.7	611.7	598.0	586.1	574.7	560.3	541.6	521.5	503.8	485.5	471.6	459.1	449.8
19	644.8	629.1	615.6	604.2	589.7	577.0	564.8	549.0	528.7	507.7	489.7	471.3	457.9	445.0	435.5
20	641.3	624.3	609.0	596.7	581.0	567.7	554.1	537.0	516.5	495.8	477.2	459.6	445.8	433.2	422.4
21	637.6	618.9	602.0	588.8	571.6	557.9	543.4	525.1	504.7	484.2	465.3	448.4	434.2	421.3	410.0
22	634.0	613.8	595.9	581.6	563.4	548.8	533.4	514.1	493.4	471.7	453.1	436.0	421.2	407.8	396.8
23	631.0	609.5	590.3	575.0	556.2	540.0	524.4	503.7	482.9	460.2	441.9	424.8	409.7	396.1	384.9
24	627.8	605.1	584.5	568.1	548.3	531.2	515.0	493.8	472.9	450.6	432.6	415.9	400.7	387.0	374.7
25	624.5	600.8	578.9	561.0	540.4	522.5	505.4	483.7	463.0	440.9	423.1	406.8	391.4	377.6	364.6
26	622.4	597.2	573.9	554.9	533.4	514.3	496.8	474.5	453.5	431.4	413.6	397.2	381.9	367.2	354.4
27	621.2	594.0	569.4	549.2	527.0	507.0	488.8	466.2	444.5	423.4	405.5	389.2	373.4	358.0	345.4
28	619.7	590.9	564.4	543.2	520.2	500.0	481.1	458.4	436.5	416.5	399.0	382.7	366.0	350.5	337.7
29	618.8	588.3	560.2	537.6	514.0	493.3	473.6	451.1	429.3	409.5	392.2	375.4	357.7	342.0	330.1
30	619.4	586.8	557.1	533.4	509.1	487.7	467.3	444.5	422.7	402.9	385.6	367.4	349.0	333.5	322.4
31	619.9	585.5	554.4	530.0	504.7	482.8	461.4	438.4	416.8	397.4	380.1	360.5	341.9	326.7	316.1
32	620.5	584.9	552.1	526.8	500.8	478.5	456.4	433.1	411.9	393.0	375.1	354.7	336.0	320.7	311.3
33	623.0	585.6	551.7	525.0	498.1	474.9	452.1	428.6	407.6	388.6	369.7	348.0	329.2	315.0	307.6
34	627.2	587.6	552.7	524.6	496.9	472.7	448.8	424.3	404.0	384.7	364.3	341.4	323.0	311.0	305.0
35	631.1	589.8	553.7	524.7	496.3	471.1	446.0	421.0	401.4	381.8	360.1	337.0	318.9	308.9	304.1
36	635.4	592.9	555.6	526.3	497.1	470.6	444.1	418.9	400.0	379.6	356.6	333.4	316.3	307.6	304.7

Candela Tabulations (Continued)

	150	155	160	165	170	175	180
0	662.1	662.1	662.1	662.1	662.1	662.1	662.1
1	659.1	659.3	658.3	657.1	656.4	656.0	653.0
2	654.9	654.5	653.4	652.2	651.3	650.6	647.6
3	648.9	648.4	646.7	645.3	643.8	643.5	639.1
4	641.4	640.6	638.7	636.4	634.9	634.1	627.8
5	633.1	631.4	629.2	625.7	625.2	623.2	616.0
6	622.9	620.0	617.3	613.1	611.8	609.9	601.2
7	609.3	605.5	601.8	596.9	593.6	593.1	580.0
8	593.8	588.8	584.0	578.2	574.6	573.1	558.4
9	578.6	571.8	566.0	559.4	557.0	554.2	540.9
10	560.9	553.6	546.9	540.7	536.7	535.6	523.3
11	541.7	534.5	527.3	522.1	517.0	516.8	503.8
12	525.1	517.7	510.4	505.3	501.6	500.0	489.2
13	510.6	503.0	496.3	491.2	488.1	485.8	477.7
14	495.2	488.6	482.1	477.7	473.3	471.8	463.2
15	479.5	473.5	467.1	462.6	457.9	456.8	447.3
16	466.5	459.8	453.4	448.2	445.1	442.4	434.3
17	454.3	446.6	440.4	434.4	432.2	429.2	422.0
18	439.8	431.8	425.6	419.6	416.1	414.8	405.4
19	425.1	417.2	410.8	404.2	400.8	399.5	388.4
20	413.1	404.3	397.7	390.5	387.7	385.2	375.3
21	401.1	391.6	384.8	377.3	374.1	371.6	362.7
22	387.2	377.9	370.5	363.5	358.7	357.1	347.0
23	374.6	365.5	357.4	350.9	345.8	343.9	334.2
24	364.7	355.5	347.4	340.6	335.8	333.4	326.3
25	354.5	345.4	337.6	331.0	326.3	324.3	319.1
26	343.7	335.6	328.2	322.2	317.5	316.1	311.0
27	334.7	327.7	320.9	315.1	311.3	309.6	305.5
28	327.9	321.3	315.2	310.0	306.5	304.8	302.0
29	321.1	315.1	310.1	305.5	302.2	300.8	298.3
30	314.1	309.7	305.8	302.1	299.2	297.9	295.8
31	309.3	306.0	303.2	300.3	297.8	296.4	294.6
32	306.0	303.4	301.9	299.5	297.3	296.0	294.9
33	303.4	302.1	301.6	300.3	298.3	296.8	296.6
34	302.5	302.7	303.9	303.6	301.4	299.3	300.7
35	303.3	305.2	307.8	308.7	306.0	303.4	305.2
36	305.3	309.6	314.1	315.9	312.5	309.1	310.4

Candela Tabulations (Continued)

	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70
37	762.1	769.9	770.5	780.2	789.1	795.1	799.9	804.7	806.0	804.6	798.5	786.1	763.5	731.1	687.1
38	774.8	782.1	782.0	792.3	801.7	808.8	814.7	819.4	820.9	818.1	811.9	798.9	775.4	742.4	696.2
39	787.6	792.9	791.5	802.2	812.8	820.7	828.0	833.3	834.9	830.8	825.0	811.0	787.0	752.6	705.1
40	799.1	802.6	800.9	812.9	824.8	833.0	841.2	848.6	849.5	844.8	838.8	824.1	799.7	764.0	714.6
41	808.2	812.4	811.7	824.0	836.8	846.2	855.9	864.5	865.8	861.9	854.2	840.4	814.2	777.8	725.6
42	816.5	820.1	821.3	833.7	847.8	858.7	870.0	880.8	885.0	881.3	872.7	858.3	830.1	791.4	737.8
43	823.3	825.0	829.0	841.9	857.8	870.3	885.3	895.9	902.2	898.3	891.2	876.9	846.0	805.4	750.9
44	826.4	827.0	834.1	848.1	867.6	885.2	900.4	913.8	919.9	917.4	910.4	896.4	865.2	823.0	767.1
45	826.4	824.6	834.2	850.2	875.3	896.7	916.2	932.8	939.2	939.4	932.2	920.1	890.2	843.5	785.9
46	822.2	818.1	829.6	849.8	878.5	904.9	929.3	949.2	959.1	960.9	955.8	945.0	915.6	866.5	807.0
47	812.5	808.0	821.4	845.4	878.3	910.5	941.3	964.5	981.6	984.6	982.2	975.1	943.7	895.7	832.1
48	798.1	790.2	806.3	833.0	871.5	910.3	949.6	981.7	1003.7	1010.0	1011.2	1008.3	980.8	930.6	863.6
49	780.7	768.2	785.2	816.7	860.3	903.7	951.9	993.2	1024.1	1037.0	1043.1	1045.8	1022.7	971.1	901.7
50	758.0	745.3	763.6	798.5	845.1	893.3	949.2	999.7	1039.9	1061.3	1076.4	1083.0	1068.8	1014.7	941.1
51	730.5	717.4	737.7	773.1	820.7	876.3	939.4	999.2	1052.0	1086.2	1111.4	1128.0	1121.4	1071.0	987.7
52	697.8	679.1	702.6	738.1	790.9	849.6	920.3	990.4	1059.5	1108.9	1150.0	1183.0	1183.4	1136.8	1042.1
53	660.5	639.5	664.1	701.9	757.9	819.2	896.4	977.9	1060.3	1126.8	1186.4	1236.0	1248.3	1200.7	1103.2
54	618.1	600.9	627.8	664.8	721.2	787.3	870.6	961.3	1056.7	1142.7	1222.6	1287.7	1314.7	1269.8	1162.5
55	574.1	553.7	583.8	616.8	674.4	746.5	835.0	933.0	1043.5	1151.8	1255.3	1341.8	1387.2	1346.9	1226.8
56	524.8	500.9	528.6	563.9	622.5	697.8	790.5	898.3	1021.3	1152.1	1282.9	1397.9	1462.6	1423.7	1292.6
57	473.0	455.5	477.6	515.5	572.3	652.5	746.2	865.0	995.7	1145.7	1304.0	1449.1	1528.4	1490.5	1350.4
58	423.5	405.4	429.5	465.8	518.2	601.7	696.4	820.5	959.9	1129.7	1316.5	1490.5	1586.7	1550.1	1400.5
59	373.6	348.9	372.2	409.1	459.3	539.0	635.5	759.7	911.1	1099.0	1317.7	1522.1	1641.3	1601.9	1445.3
60	322.2	299.5	319.6	359.1	404.3	476.7	573.2	698.9	861.9	1063.3	1308.3	1542.0	1680.1	1636.6	1476.5
61	279.2	261.1	278.4	312.4	351.3	422.2	515.0	640.3	810.7	1022.4	1286.7	1550.1	1701.3	1658.0	1490.7
62	241.2	224.9	241.3	264.7	300.2	363.3	452.3	570.4	742.4	964.9	1244.7	1532.3	1698.2	1659.3	1490.5
63	207.9	193.9	206.6	226.0	257.8	307.8	389.0	502.7	669.9	900.2	1187.5	1485.4	1666.3	1631.4	1468.9
64	182.0	172.6	182.7	199.1	224.8	268.3	337.6	444.0	605.6	836.2	1121.4	1430.9	1615.3	1583.6	1426.4
65	161.8	155.3	163.7	175.5	196.7	234.2	291.2	384.5	542.1	762.3	1044.0	1357.2	1540.8	1514.5	1367.8
66	144.8	140.6	146.7	155.0	172.0	201.8	250.8	330.4	476.2	674.1	948.2	1254.6	1438.3	1418.7	1286.3
67	132.3	129.7	134.7	140.4	153.1	177.7	219.5	291.2	418.6	592.5	850.4	1139.5	1327.2	1309.0	1188.3
68	123.1	120.7	125.7	129.5	138.5	158.3	192.3	256.8	361.4	519.2	745.9	1023.3	1209.5	1191.2	1085.7
69	113.6	110.4	115.5	119.4	126.2	140.5	167.5	220.2	304.4	441.0	640.2	892.5	1074.4	1072.8	974.5
70	103.7	100.0	104.8	110.0	116.3	126.9	147.5	188.9	261.8	372.7	545.1	774.3	944.4	960.7	870.7
71	94.9	90.3	95.0	101.0	107.6	117.9	133.8	165.2	227.6	313.9	460.9	666.8	818.4	852.5	774.1
72	84.8	79.2	83.7	89.4	98.1	108.8	120.6	143.3	192.4	259.8	381.1	561.2	694.3	739.9	676.5
73	72.9	67.9	71.7	77.1	87.6	98.9	108.5	124.9	160.6	215.6	312.4	459.7	589.6	640.5	585.7

Candela Tabulations (Continued)

	75	80	85	90	95	100	105	110	115	120	125	130	135	140	145
37	642.1	597.6	559.7	529.6	499.4	471.5	443.6	418.2	399.5	377.5	353.1	329.8	314.6	307.8	306.5
38	649.5	603.2	564.7	533.6	502.8	473.2	443.9	418.5	399.9	375.9	350.3	327.4	314.1	309.2	309.4
39	656.7	609.4	570.0	538.6	507.0	475.9	444.9	419.8	401.0	375.0	348.8	326.7	315.2	311.5	313.1
40	665.1	617.0	576.8	545.4	513.2	480.2	447.3	422.5	403.0	374.8	348.4	326.9	317.9	315.3	319.0
41	675.1	625.8	585.6	554.1	521.3	485.9	451.5	426.3	405.3	375.5	348.9	328.2	321.2	321.2	326.4
42	685.2	635.2	594.9	563.4	530.3	492.0	456.2	430.5	407.7	377.0	350.5	331.2	325.0	327.0	332.3
43	696.4	646.3	605.3	574.2	540.7	499.5	461.5	435.6	411.0	379.9	354.3	335.8	329.4	332.3	336.8
44	711.3	660.4	619.3	588.0	553.9	508.7	467.6	441.6	415.0	384.1	359.5	340.6	334.5	337.0	338.6
45	728.8	676.1	635.4	604.1	568.7	518.8	474.6	448.2	419.0	389.4	365.0	344.6	338.8	339.1	336.3
46	747.0	693.7	651.7	619.9	583.9	529.1	483.0	455.7	424.0	395.7	370.5	348.0	341.7	338.0	331.4
47	768.4	714.4	670.3	636.9	599.3	540.0	493.1	463.8	429.3	401.9	375.5	352.4	342.2	334.6	324.8
48	796.6	739.2	692.8	656.0	615.3	551.5	502.6	471.4	434.6	406.8	378.5	354.8	340.3	328.6	316.0
49	830.0	765.9	716.1	676.5	630.8	562.6	511.2	477.7	439.4	410.2	379.3	353.9	336.3	322.1	306.1
50	865.7	794.5	740.4	697.0	647.0	574.1	519.9	483.9	444.5	412.9	378.3	351.4	330.8	313.6	297.2
51	905.4	828.6	767.8	719.1	664.3	586.0	529.4	489.8	448.7	414.0	375.0	345.6	322.4	303.6	287.8
52	952.8	870.6	800.7	742.9	680.7	596.7	538.2	493.8	451.2	412.2	367.4	334.7	312.0	294.0	276.9
53	1004.6	912.8	835.2	767.4	695.1	604.7	544.1	495.8	452.0	407.8	357.8	324.2	303.2	284.3	267.3
54	1054.2	957.7	871.7	792.2	709.6	611.7	547.8	496.9	451.2	402.2	349.6	315.9	293.8	275.5	259.6
55	1108.1	1006.0	910.5	819.6	724.4	617.2	549.9	496.8	448.2	395.0	341.5	305.9	283.6	268.0	252.9
56	1160.6	1051.1	948.2	844.7	735.9	619.8	549.2	493.8	441.3	385.3	330.5	294.2	274.5	262.8	248.4
57	1206.4	1093.2	983.3	865.7	742.3	617.8	543.2	485.7	432.5	374.6	318.7	284.4	268.9	259.5	245.7
58	1248.5	1132.5	1015.8	881.3	746.2	613.0	532.5	475.3	422.8	363.4	308.6	277.5	265.4	256.3	244.3
59	1285.5	1164.7	1042.2	893.1	746.6	605.1	516.5	461.9	411.0	351.7	300.1	271.6	261.6	253.7	243.2
60	1308.4	1184.6	1057.0	896.7	740.6	592.0	495.9	443.4	396.1	339.3	291.8	266.9	257.2	251.4	241.5
61	1317.6	1193.8	1061.2	890.9	730.3	573.8	468.5	417.8	376.9	325.6	283.4	262.9	253.5	249.1	239.5
62	1318.5	1193.6	1058.3	878.9	715.7	551.0	434.4	387.5	354.4	308.8	274.1	258.5	250.3	246.1	236.8
63	1301.9	1178.3	1043.5	856.5	693.4	522.5	398.3	355.4	330.0	292.0	264.7	253.2	247.2	242.8	233.6
64	1264.8	1148.9	1015.9	826.4	664.1	489.5	364.8	325.3	305.6	276.8	255.7	247.7	243.9	239.5	229.8
65	1215.5	1107.2	977.7	788.0	629.1	452.0	331.6	297.0	281.0	260.1	245.8	241.7	239.2	235.1	225.8
66	1151.2	1048.6	927.1	744.4	588.6	411.3	301.5	271.9	257.0	241.6	234.5	234.6	232.8	229.2	220.9
67	1066.1	975.6	865.9	694.4	543.4	370.0	273.3	249.1	235.5	225.3	222.8	226.8	225.6	222.4	214.8
68	972.3	891.1	797.3	640.0	495.0	330.4	246.2	226.3	216.0	210.8	211.8	218.0	218.2	214.7	208.1
69	876.9	801.6	720.2	579.4	445.3	292.9	222.9	205.9	198.8	197.6	200.2	207.4	208.4	206.4	201.4
70	786.3	718.8	643.8	518.4	397.9	259.2	201.1	188.1	182.7	186.5	189.5	197.2	197.7	197.7	194.8
71	700.5	643.4	574.3	460.7	352.6	228.8	179.8	169.9	167.6	173.8	179.0	187.0	186.4	187.2	187.6
72	608.7	565.3	503.1	406.1	309.5	202.7	158.8	151.9	152.1	160.5	167.3	175.8	174.6	175.2	177.4
73	524.2	492.0	436.2	356.7	271.5	179.8	140.4	135.9	138.5	148.6	156.2	163.7	163.4	164.4	165.5

Candela Tabulations (Continued)

	150	155	160	165	170	175	180
37	309.9	317.1	323.6	324.7	320.9	316.2	317.2
38	316.3	325.4	331.9	332.0	327.0	321.9	321.0
39	322.4	332.1	338.1	336.9	330.6	324.8	321.8
40	329.6	338.4	342.5	339.4	331.5	325.1	320.2
41	335.8	342.0	343.1	337.8	328.8	322.1	315.0
42	339.3	342.1	339.8	332.6	324.1	316.7	308.2
43	339.9	339.1	334.1	325.6	317.5	310.1	301.8
44	337.3	331.7	323.9	314.7	307.2	300.8	290.4
45	330.4	321.5	311.1	301.5	294.4	288.3	275.7
46	322.3	310.6	299.1	288.4	282.6	275.6	263.7
47	313.7	299.0	286.0	276.0	269.7	263.2	252.3
48	302.2	285.6	272.3	262.4	254.6	249.0	237.4
49	290.4	273.9	259.7	249.3	242.4	237.4	228.5
50	280.5	263.6	248.5	238.8	233.6	229.6	224.3
51	270.0	252.6	238.7	231.3	227.4	225.1	221.8
52	258.2	242.4	231.8	226.2	223.2	221.5	218.4
53	248.8	235.3	227.5	223.0	220.2	218.3	214.4
54	241.9	230.9	224.5	220.3	217.4	214.8	211.3
55	236.7	227.8	222.0	217.3	213.7	210.7	207.3
56	233.1	225.4	219.7	214.4	210.3	206.9	203.0
57	231.0	223.8	217.7	212.3	207.3	203.5	199.7
58	230.0	222.0	215.6	210.1	204.3	200.4	196.2
59	229.2	220.1	213.3	207.4	200.8	196.8	192.1
60	228.4	218.3	211.1	204.5	197.4	193.4	189.1
61	227.1	216.3	208.9	202.0	194.5	190.3	187.3
62	225.1	213.8	205.5	199.3	191.7	188.0	184.6
63	221.9	210.6	201.9	196.2	189.8	186.1	182.6
64	218.3	206.7	198.9	194.2	188.3	184.7	182.0
65	214.0	202.7	195.8	192.3	187.2	183.4	180.9
66	209.0	198.6	192.4	189.9	184.9	181.6	174.1
67	204.5	195.0	189.3	187.0	180.8	177.9	168.5
68	199.9	191.5	186.2	182.2	176.0	171.8	161.8
69	194.2	187.5	180.4	175.0	169.6	163.0	153.2
70	189.0	181.8	172.3	169.4	164.0	154.9	145.9
71	183.6	173.8	164.5	163.8	158.8	148.2	140.2
72	175.0	164.0	156.6	156.0	149.1	139.4	129.7
73	162.1	153.2	147.4	142.7	133.0	126.4	112.7

Candela Tabulations (Continued)

	0	5	10	15	20	25	30	35	40	45	50	55	60	65	70
74	62.3	57.7	61.2	66.5	76.3	89.0	98.9	110.7	133.9	181.6	259.8	383.9	504.2	555.2	509.9
75	53.2	48.7	51.8	55.9	64.7	78.0	88.8	97.8	112.0	152.8	219.2	319.4	417.9	470.8	436.5
76	44.1	39.8	42.4	45.8	53.1	65.0	77.2	85.4	95.6	127.7	184.6	258.1	334.2	382.3	364.6
77	35.9	32.4	34.1	37.4	43.4	53.4	65.3	74.2	83.4	107.6	154.5	209.9	266.4	303.5	299.7
78	29.4	26.2	27.6	29.6	34.2	42.2	53.0	62.8	71.3	89.3	124.8	168.3	212.5	235.5	240.7
79	23.3	20.4	21.4	22.7	26.0	31.8	41.1	50.7	57.6	70.7	98.2	129.9	165.2	182.3	186.5
80	18.2	15.3	16.1	17.3	19.7	23.8	31.4	39.6	45.4	54.0	75.4	98.0	127.5	143.0	145.4
81	13.6	11.4	11.9	12.9	14.8	17.6	23.1	30.0	34.9	40.7	55.4	70.5	92.8	107.6	109.7
82	10.0	8.3	8.5	9.3	10.5	12.3	15.8	21.0	25.5	29.3	38.7	47.1	56.5	68.1	73.6
83	7.2	5.8	6.0	6.6	7.5	8.6	10.8	13.9	17.0	19.6	25.2	29.7	34.7	40.9	45.3
84	5.1	4.2	4.4	4.8	5.4	6.2	7.3	9.1	10.5	12.4	15.8	18.2	21.4	24.3	26.8
85	3.7	3.1	3.4	3.7	4.1	4.6	5.3	6.0	6.8	7.9	9.4	11.0	13.4	15.2	16.3
86	2.5	2.3	2.6	2.9	3.2	3.6	4.0	4.3	4.7	5.2	6.1	7.2	8.3	9.6	10.1
87	1.6	1.6	2.0	2.4	2.6	2.8	3.2	3.5	3.8	3.9	4.3	4.9	5.5	5.9	6.1
88	1.0	1.1	1.5	1.9	2.0	2.1	2.5	2.8	3.0	3.1	3.3	3.7	4.0	4.1	4.2
89	0.7	0.9	1.2	1.4	1.5	1.5	1.8	2.3	2.5	2.5	2.7	3.1	3.2	3.2	3.2
90	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Candela Tabulations (Continued)

	75	80	85	90	95	100	105	110	115	120	125	130	135	140	145
74	457.2	430.3	380.6	313.5	238.4	158.7	124.9	122.5	127.2	138.4	145.5	151.7	151.9	153.9	153.9
75	397.1	372.5	331.2	273.0	208.3	138.5	110.3	110.1	116.8	128.4	134.3	140.0	139.1	140.9	140.0
76	336.4	318.7	283.2	235.8	180.5	119.6	97.1	98.0	105.8	117.4	123.2	128.2	126.4	127.5	124.7
77	279.4	268.3	240.3	202.4	155.3	102.9	84.9	86.2	94.8	106.0	111.8	116.9	114.5	113.9	111.9
78	227.1	220.3	199.1	171.5	130.9	87.6	73.6	75.1	83.8	94.8	100.4	104.7	102.3	100.2	98.9
79	180.3	175.9	162.7	142.6	108.2	73.8	62.8	64.8	73.1	83.9	89.4	91.9	90.3	85.4	84.2
80	143.1	141.6	131.5	116.9	89.2	61.8	53.9	55.8	63.4	73.6	79.1	79.8	77.2	72.2	71.5
81	111.8	110.7	105.4	94.1	72.6	51.5	45.6	47.4	53.9	62.7	68.4	69.0	65.5	62.1	60.9
82	76.7	79.9	79.3	72.4	56.2	42.1	37.8	39.5	44.7	52.1	57.6	58.5	55.3	52.5	51.9
83	48.7	53.8	55.9	53.2	41.8	33.3	30.9	32.4	36.7	42.8	48.0	48.8	46.3	44.2	44.3
84	30.5	34.4	37.0	37.0	30.9	25.9	24.8	26.3	30.1	35.1	39.8	40.1	38.8	37.1	37.6
85	18.9	21.5	23.3	24.6	22.0	19.7	19.5	21.2	24.4	28.3	32.5	32.4	32.0	30.8	31.6
86	11.9	13.8	14.8	15.9	15.4	14.3	15.1	16.7	19.1	22.0	25.7	26.1	25.7	25.4	26.1
87	6.9	8.4	9.3	10.4	10.6	10.4	11.3	12.7	14.5	16.7	19.6	20.3	20.3	20.5	20.9
88	4.5	5.0	5.5	6.1	7.0	7.4	8.2	9.6	11.1	12.6	14.7	15.6	15.9	16.5	16.5
89	3.3	3.4	3.3	3.5	4.6	5.2	6.0	7.3	8.8	9.7	11.3	12.0	12.4	13.2	13.0
90	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

Candela Tabulations (Continued)

	150	155	160	165	170	175	180
74	150.1	141.5	137.9	129.7	118.3	112.5	98.8
75	138.3	131.6	127.1	116.1	105.7	99.4	90.1
76	124.7	121.5	114.0	103.0	94.3	89.2	81.9
77	110.0	110.4	101.6	91.7	86.2	81.7	74.7
78	97.9	99.8	90.0	82.7	79.4	74.5	67.9
79	85.9	87.5	79.0	74.2	72.3	67.1	61.1
80	72.5	76.0	68.8	66.3	65.3	60.5	54.7
81	62.3	64.3	59.5	58.3	58.6	54.3	49.2
82	53.6	54.3	50.9	50.6	51.7	47.9	43.7
83	45.6	45.8	43.5	43.6	44.2	41.8	37.4
84	38.5	38.0	37.3	37.5	37.8	36.0	31.8
85	31.8	31.0	31.5	31.9	31.7	30.6	26.7
86	25.8	25.3	26.1	26.5	26.3	25.7	22.1
87	20.7	20.5	21.0	21.3	21.4	20.9	17.6
88	16.2	16.4	16.6	16.8	16.8	16.5	13.7
89	12.6	13.0	13.0	13.1	12.9	12.7	10.1
90	0.0	0.0	0.0	0.0	0.0	0.0	0.0

NOTE: The device under test emits no detectable uplight, as defined by ANSI/IES LM-75-19.

Test Date(s):

Equipment	Date
2M Sphere	02-01-2024
Type C Goniophotometer	02-01-2024

Integrating Sphere Equipment:

Description	Manufacturer	Model	Serial Number
2M Sphere	Labsphere	ILLUMIA PLUS 3020-195-4PI	1115184557
CCD Array Spectrometer	Labsphere	MC-9801:3683L	98010844
Lamp Power Supply	Labsphere	LPS-525-42	190615319
Programmable AC Source	Chroma	61602	616020003698
Power Analyzer	Xitron	XT2640	2641AD2006002

Goniophotometer Equipment:

Description	Manufacturer	Model	Serial Number
Type C Goniophotometer	LSI / UL	6440T	6440PN2028
Spectroradiometer	Gooch & Housego	770VIS/NIR	12415212
Spectrometer	Inphora, Inc	PDET 31	130627
Programmable AC Source	Chroma	61602	616020002300
Power Analyzer	Xitron	XT2640	2641AD2006004

Test Methods Used:

Title	Description
ANSI C82.77:2002	Harmonic Emission Limits- Related Power Quality Reqt's for Lighting Equipment
CIE Pub.13.3:1995	Method of Measuring and Specifying Color Rendering of Light Sources
CIE Pub.15:2018	Colorimetry
IES LM-58:1994	Spectroradiometric Measurements
ANSI/IES LM-79:2008	Electrical and Photometric Measurements of Solid-State Lighting Products

Reference Standard Used:

Equipment	Description
2M Sphere	Tungsten Halogen Omni-Directional 35W Calibration Lamp, Serial Number E4
Type C Goniophotometer and Spectrometer	Tungsten Halogen Omni-Directional 500W Calibration Lamp, Serial Numbers 16C293, 16C294, 16C295. For color calibration of spectrometer, 13C074.

Disclaimers:

This report must not be used by the customer to claim product certification, approval, or endorsement by NVLAP, NIST or any agency of the federal government.

The results contained in this report pertain only to the tested sample.

This report shall not be reproduced, except in full, without written approval of the RESTL.

Exceptions:


Data in this report tested under Non-Standard Conditions (i.e. temperature outside the allowed acceptance interval for the equipment/test) are identified with (~).

Data in this report not covered by the NVLAP accreditation, are identified with (*).

In the event testing is subcontracted, subcontracted equipment was used, or performed by the subcontracted laboratory identified in the equipment list of this report, test results in this report marked with the symbol (^).

Additional Comments:

The photos below are intended to show the orientation and fixturing/set-up of the units under test. These are critical to understanding the results of the test given the sensitivity of many products and measurement systems to orientation and set-up considerations, and also for reproducing the conditions of the test.



Document Revision History:







Each subsequent revision of this report replaces the preceding report.

Date	Rev	DCN #	Change at the time of this test	By	Approval
02/02/2024	A	DMS	Origination	J. Rocco	M. Hubbard

ANSI/IES TM-30-18 Color Rendition Report

Source: OSQP-C-3L-27K7-3R-UL (Light Engine)
Date: 2/2/2024

Manufacturer: Cree Lighting
Test: PL18136-001



Notes:

x	0.4595
y	0.4155
u'	0.2601
v'	0.5292

CIE 13.3-1995 (CRI)	
R _a	72
R _g	-32